

CANOPY DETAILS

LOW LEVEL STAINLESS STEEL EXTRACT PLENUM LOCATED 1400MM FROM FFL AND MEASURING 2800MM X 600MM X 450MM.

COMPLETE WITH STAINLESS STEEL BAFFLE FILTERS AND GREASE COLLECTION DRAWERS

AIRFLOW
EXTRACT 0.653M3/S @ 125 PA
SUPPLY 0.56M3/S (40PA IF THROUGH THE CANOPY)

2 NUMBER EXTRACT SPIGOTS - 250MM X 250MM X 50MM

SPIGOTS 50MM SLIP SPIGOTS

CANOPY WEIGHT 140KG - 6 FIXING POINTS
CANOPY MANUFACTURED IN ACCORDANCE AND COMPLIANT TO DW172

CANOPY SUPPORTED BY DROP RODS TO SLAB FIXINGS

NO ALLOWANCE FOR STAINLESS STEEL WALL CLADDING TO AREA ABOVE THE LOW LEVEL PLENUM.

NO ALLOWANCE FOR INFILL BETWEEN THE TOP OF THE CANOPY AND THE CEILING.



FRONT ELEVATION



SIDE ELEVATION

Revision	Details Of Revision	Drawn By	Date	Checked By	Date

Revision	Details Of Revision	Drawn By	Date	Checked By	Date

This drawing is for design intent only and is subject to final contractors drawings.

Please do not scale from this drawing. All dimensions are in millimeters. Site dimensions must be checked and any variance reported.

Client:	Jackson Lane
Project:	Kitchen & Bar
Title:	Catering Ventilation Canopy
Drawing Number:	IC0853
Scale:	
Date:	05-03-2021

Intelligent Catering - This drawing is supplied as private & confidential and must not be copied or communicated to any other person or used for any other purpose without express written approval.

intelligent catering
Tel: 07747767046
E-mail: rburgess@intelligentcatering.co.uk
5 Crofters Close, Deepcut, Surrey, GU16 6GH